



## **Saint Regis Mohawk Tribe – Grants & Contracts**

412 State Route 37 ♦ Akwesasne, New York 13655

Tel. (518) 358-2272 ♦ Fax (518) 358-6234

### **ADDENDUM NO. 5**

**SRMT 12-01  
CENTER OF EXCELLENCE FOR  
DIABETES CARE AND PREVENTION  
AKWESASNE, NEW YORK**

**March 19, 2012**

- A. The following is hereby incorporated into the bid documents for the above-noted project:**
- 1. Please revise drawing E-603, Panel Schedules & Schematics, Detail 1 – One Line Diagram as follows: change the Main Circuit Breaker designation for panel MDP from 800A-3P MCB to 1000A-3P MCB.**
  - 2. Please revise drawing E-602, Panel Schedules & Schematics, schedule for Panel MP-1 as follows: change the Mains from 200A BKR to 200A LUGS.**
  - 3. Please revise the note on Typical Wall Section drawing 1/A-302 which reads “1 ½” Polyiso Board Sheathing, Typ. (R-7.5)” to read as follows: “1” Polyiso. Board Sheathing Typ. (R-6.5)”**
  - 4. Please delete specification Section 22 50 01, Swimming Pool Construction and replace it with the attached revised specification Section 22 50 01, Swimming Pool Construction.**
  - 5. Please delete specification Section 22 50 03, Swimming Pool Filtration and Treatment Systems and replace it with the attached revised specification Section 22 50 03, Swimming Pool Filtration and Treatment Systems.**
  - 6. Please add the attached Energy Recovery Ventilator Schedule (ERV) to drawing M-602**
  - 7. Amend bid closing date from 3:30 p.m. on Thursday, March 22, 2012 to 3:30 p.m. on Tuesday, March 27, 2012.**
- B. That all other terms and conditions remain unchanged.**

**Please acknowledge receipt and acceptance of this addendum no. 5 on page 1 of the Bid Form.**